



EPA Tier 2 Emission Data
Fire Pump NSPS Compliant

CFP6E-F15 Fire Pump Driver

Type: 4 Cycle; In-Line; 6 Cylinder
Aspiration: Turbocharged, Charge Air Cooled

15 PPM Diesel Fuel													
RPM	BHP	Fuel Consumption		D2 Cycle Exhaust Emissions						Exhaust			
		Gal/Hr	L/hr	Grams per BHP - HR			Grams per kW - HR			Temperature		Gas Flow	
				NMHC+NOx	CO	PM	NMHC+NOx	CO	PM	°F	°C	CFM	L/sec
1760	175	8.5	32.2	3.924	0.447	0.065	5.262	0.600	0.088	818	437	924	436
2100	200	9.8	37.1							850	454	1110	524
2350	200	9.9	37.5							831	444	1197	565
2600	200	10.3	39.0							857	458	1294	611

The emissions values above are based on CARB approved calculations for converting EPA (500 ppm) fuel to CARB (15 ppm) fuel.

300-500 PPM Diesel Fuel													
RPM	BHP	Fuel Consumption		D2 Cycle Exhaust Emissions						Exhaust			
		Gal/Hr	L/hr	Grams per BHP - HR			Grams per kW - HR			Temperature		Gas Flow	
				NMHC+NOx	CO	PM	NMHC+NOx	CO	PM	°F	°C	CFM	L/sec
1760	175	8.5	32.2	4.265	0.447	0.075	5.720	0.600	0.100	818	437	924	436
2100	200	9.8	37.1							850	454	1110	524
2350	200	9.9	37.5							831	444	1197	565
2600	200	10.3	39.0							857	458	1294	611

QSB5.9 Base Model Manufactured by Cummins Inc.
- Using fuel rating 90847

Reference EPA Standard Engine Family: 5CEXL0359ABE

No special options needed to meet current regulation emissions for all 50 states

Test Methods:

EPA/CARB Nonroad emissions recorded per 40CFR89 (ref. ISO8178-1) and weighted at load points prescribed in Subpart E, Appendix A, for Constant Speed Engines (ref. ISO8178-4, D2).

Diesel Fuel Specifications:

Cetane Number: 40-48
Reference: ASTM D975 No. 2-D

Reference Conditions:

Air Inlet Temperature: 25°C (77°F)
Fuel Inlet Temperature: 40°C (104°F)
Barometric Pressure: 100 kPa (29.53 in Hg)
Humidity: 10.7 g/kg (75 grains H₂O/lb) of dry air; required for NOx correction
Restrictions: Intake Restriction set to a maximum allowable limit for clean filter; Exhaust Back Pressure set to maximum allowable limit.

Tests conducted using alternate test methods, instrumentation, fuel or reference conditions can yield different results.